

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx BAS 08.0034X

Issue No: 12

Certificate history:

Status:

Current

Issue No. 12 (2018-08-17) Issue No. 11 (2017-11-01)

Date of Issue:

2018-08-17

Page 1 of 4

Issue No. 10 (2017-05-16)

Issue No. 9 (2015-06-17)

Issue No. 8 (2013-01-15)

Issue No. 7 (2012-10-12)

Issue No. 6 (2012-02-02)

Issue No. 5 (2011-01-24)

Issue No. 4 (2009-11-30) Issue No. 3 (2009-02-05)

Applicant:

Hansford Sensors Limited

Artisan

Hillbottom Road Sands Industrial Estate

Bucks HP12 4HJ **United Kingdom**

Equipment:

HS-420 Series Accelerometer

Optional accessory:

Fuse Box

Type of Protection:

Intrinsic Safety, gas and dust

Marking:

Ex ia I Ma (-40°C ≤ Ta ≤ +60°C)

Ex ia IIC T4/T6 Ga (-40°C ≤ Ta ≤ +110°C/60°C)

Ex ia IIIC T130°C/T80°C IP65 Da (-40°C \leq Ta \leq +110°C/60°C)

Approved for issue on behalf of the IECEx

Certification Body:

R S Sinclair

D BREARLEY Certification Manager

Position:

Technical Manager

Signature:

(for printed version)

Date:

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

SGS Baseefa Limited Rockhead Business Park Staden Lane Buxton, Derbyshire, SK17 9RZ United Kingdom





Certificate No:

IECEx BAS 08.0034X

Issue No: 12

Date of Issue:

2018-08-17

Page 2 of 4

Manufacturer:

Hansford Sensors Limited

Artisan

Hillbottom Road Sands Industrial Estate

Bucks HP12 4HJ **United Kingdom**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11: 2011

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/BAS/ExTR08.0059/00

GB/BAS/ExTR08.0112/00

GB/BAS/ExTR08.0181/00

GB/BAS/ExTR09.0014/00

GB/BAS/ExTR11.0013/00

GB/BAS/ExTR12.0005/00

GB/BAS/ExTR12.0254/00

GB/BAS/ExTR15.0175/00

GB/BAS/ExTR17.0322/00

GB/BAS/ExTR18.0140/00

Quality Assessment Report:

GB/BAS/QAR07.0040/07



Certificate No:

IECEx BAS 08.0034X

Issue No: 12

Date of Issue:

2018-08-17

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The HS-420 Series Accelerometers are designed to measure velocity or acceleration by converting the signal generated by the compression of a piezo electric crystal by a given seismic mass and output a 4 to 20mA signal proportional to velocity or acceleration to the monitoring equipment.

The accelerometer comprises a piezo electric crystal connected to a signal conditioning board all contained within a stainless steel enclosure of various shapes measuring approximately 33cm³. The enclosure is a fully welded construction.

Electrical connections are made to the apparatus either via an IP65 rated connector or via an integral cable which is encapsulated in the end of the apparatus.

For terminal parameters see Annex.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The free end of the cable on the integral cable version of the apparatus must be terminated in an appropriately certified dust proof enclosure.



Certificate No: IECEx BAS 08.0034X Issue No: 12

Date of Issue: 2018-08-17 Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Variation 12.1

To permit minor mechanical changes to the assembly introduced at Issue 11 of this certificate, involving the use of additional sleeving on inner wires and a change to the notes on the circuit diagram relating to total capacitance.

An alternative assessment of the Mining variants is added which does not require the use of encapsulation.

Additionally, an alternative Temperature Class T4 is introduced for the Group II & III variants for an increased ambient temperature (110°C).

ExTR: GB/BAS/ExTR18.0140/00	File Reference: 18/0450

Annex

IECEx BAS 08.0034X Annex Issue 4.pdf

SGS Baseefa Limited

Rockhead Business Park Staden lane, Buxton, Derbyshire **SK17 9RZ United Kingdom**



Date: 1 November 2017

ANNEX to IECEx BAS 08.0034X

Issue No. 4

The Group II & III versions of the apparatus (excluding cable) have the following terminal parameters:

 $U_i = 28V$

 $C_i = 0$

 $I_i = 115 \text{mA}$

 $L_i = 0$

 $P_{i} = 0.65W$

The HS-420IT or HS-422IT Accelerometer, with an integral temperature sensor and 25m of cable has the following terminal parameters for all four electrical connections considered as a single intrinsically safe circuit:

 $U_i = 44V$

 $C_i = 3nF$

 $I_i = 117 \text{mA}$

 $L_i/R_i = 13nH/\Omega$

 $P_i = 0.722W$

The Group I version of the apparatus (excluding cable) has the following terminal parameters:

 $U_i = 16.5V$

 $P_i = 1.74W$

 $C_i = 0$ $L_i = 0$

The apparatus must be powered from a power limited source such as an appropriately certified fuse assembly containing a ≤62mA fuse, 1.74W (16.5V x 62mA x 1.7).

The Group I version of the apparatus (excluding cable) has the following alternative terminal parameters:

 $U_i = 28V$

 $C_i = 0$

 $I_i = 115 mA$

 $L_i = 0$

 $P_{i} = 0.65W$

The capacitance and inductance to resistance ratio of the different versions have the following parameters:

	Integral Cable or 2-Pin Mill Spec Connector with cable				4-Pin M12 Connector
	Polyurethane	Silicone	Armoured	PUR	Polyurethane
	Cable	Cable	Cable	Cable	Cable
Ci	= 160pF/m	= 370pF/m	= 290pF/m	= 884pF/m	= 120pF/m
Li	= 0.72μH/m	= 0.5μH/m	= 0.5μH/m	= 0.6μH/m	$= 0.7 \mu H/m$
L _i /R _i	$= 8.32 \mu H/Ω$	$= 15.4 \mu H/\Omega$	$= 15.4 \mu H/Ω$	$= 6.1 \mu H/Ω$	= 11.7μ $H/Ω$